

**MATERIAL REACTION TO FIRE CLASSIFICATION REPORT
PREPARED IN COMPLIANCE WITH AMENDED 5 OF THE FRENCH HOME OFFICE REGULATION
REGULATION DATED NOVEMBER 21ST, 2002 (OFFICIAL GAZETTE DATED DECEMBER 31, 2002)**

Valid five years from issue date

CERTIFICATE N° 23-01112 L

And 1 Appendix of 7 pages

MATERIAL presented by:

Supplied by: Vyva Fabrics
TT. Vasumweg 140, 1033 SH Amsterdam
The Netherlands

TRADE NAME:

Viper & Viper Vintage, Oxford, Cuzco, Globe

BRIEF DESCRIPTION:

100 % polyester knitting with inherent flame retardant PVC coating on one side.

Nominal surface weight : 680 g/m²

Nominal thickness : 1mm

Colours : Various

TEST REPORT :

N° 23-01112 E1V1 on the May 31st 2023

TESTS :

Electrical burner test

CLASSIFICATION

M2

**Classification valid for any application for which the product is not subjected
to the CE marking of the Construction products**

CLASSIFICATION DURATION (article 5 of appendix 2) : unlimited unless otherwise specified

given the criteria resulting from the tests described in the enclosed test report.

The classification indicated does not mean that materials marketed comply with the test samples and must not be considered as a qualification certificate as defined by French law dated March 14, 2016.

N.B.: Only integral copies of this document may be made by photocopying the classification report and/or the classification report and enclosed test report.

Issued in Lyon, France, on the May 31st 2023



Olivier PALLAS
Tests and Trials Engineer